



**PROPRIETARY**

**PLEASE NOTE**

ALL FIELD WIRING SHALL BE THINWALL THRU OR IN WIRE TYPE (OR SHIELDED CABLE WIRE) NOTED ON SCHEMATIC RELATED TO EACH END FOR EACH CONNECTION BEING MADE. WIRING SHALL BE INSTALLED PER NEC AND LOCAL CODE REQUIREMENTS. ALL CONTROL WIRING SHALL BE AS FOLLOWS:

GAUGE	MAX. DISTANCE
18	50'
16	75'
14	125'
12	200'

DO NOT RUN LINE VOLTAGE WIRES WITH CONTROL WIRES

**LEGEND**

SYMBOL	DEFINED AS
⊖	(2ND) EARTH GROUND
○	ONLY 208V WIRELESS ROD
○	WIRES NUMBERS
○	TERMINALS IN CONTROL PANEL
○	TERMINALS IN REMOTE PANEL
---	REMOTE PANEL WIRING
◆	FIELD WIRING BETWEEN TERMINALS IN REMOTE PANEL & TERMINALS IN UNIT CONTROL PANEL
⊞	SHIELDED CABLE
⊞	FIELD CONNECTION

**UNIT SET POINTS**

DEVICE	RECOMMENDED SETTING
HAFS / LAFS	0.90" / 0.40" WC
HIL	130° F
MWS	65° F
PPS-HIGH	CLOSES ABOVE 0.75" WC
PPS-LOW	CLOSES BELOW 0.60" WC

T3-DX -3PH BASE CABINET
CAST ALUMINUM BURNER
0.75" FM/ETL DIRECT SPARK IGNITION MANIFOLD
UNPAINTED UNIT
BASE CABINET INSULATION (1" FOIL FACE)
2HP 208/3/60 TEFC PREMIUM EFFICIENT IMPORT MOTOR
RUBBER INTERNAL VIBRATION ISOLATORS
STANDARD DUTY FAN
DWDI FORWARD CURVED BLOWER (G15)
<b>COOLING SECTION</b>
DRAW-THRU COOLING SECTION
CBM3 COIL SECTION
COOLING COIL
(2)5 TON 208-230/1 CONDENSING UNIT (10 TONGS & 2 CIRCUITS TOTAL)
SPLIT SYSTEM - FIELD INSTALLED BY OTHERS
COIL SECTION - 1" FOIL FACE INSULATION
HINGED CBM3 DOOR
MOTORIZED INLET DAMPER
<b>INLET HOOD</b>
2" ALUMINUM CLEANABLE FILTERS
<b>UNIT CONTROLS</b>
DELETE REMOTE PANEL
FAN ENABLE DRY CONTRACT (SIGNAL BY OTHERS)
BURNER ENABLE DRY CONTRACT (SIGNAL BY OTHERS)
MAXITROL 14L - DISCHARGE TEMP. CONTROL (UNIT)
COOLING STAT (SHIPPED LOOSE)
MILD WEATHER STAT
FIRE PROTECTION INTERLOCK
NON-FUSED DISCONNECT SWITCH
NO POWER WIRING HARNESS
NO REMOTE WIRING HARNESS
<b>SPECIAL LINE ITEMS</b>
(1)A2L REFRIGERANT LEAK CIRCUIT

"IT IS THE RESPONSIBILITY OF THE ARCHITECT/OWNER TO ENSURE THAT THE FOOD RELEASES FROM LIMITED-COMBUSTIBLE MATERIALS IS IN COMPLIANCE WITH LOCAL CODE REQUIREMENTS."

"ALL EQUIPMENT IS UL LISTED COMPONENTS. NAKS HOODS ARE BUILT IN COMPLIANCE WITH: NFPA 96-8 & UL710 AND ARE RECOGNIZED BY ONE OR MORE OF THE FOLLOWING - NSF INTERNATIONAL -UL -OPENINGS ARE RECOMMENDED SIZES. DUCT OPENINGS TO BE CUT AND DUCTS INSTALLED IN FIELD"

NSF, UL LISTED, IAPMO

REVISIONS	
NO.	DESCRIPTION

**NORTH AMERICAN**  
152 BEAVER CREEK, STANFORD, IN 46084-6307  
TEL: 317-336-8600 FAX: 317-336-2300

**EQUIPMENT SCHEDULE**

T3-DX WIRING

CONTRACT NO. - ITEM NO. -  
 LOC. -  
 QUANT. -  
 DATE -

DWG# - SHIT - GF -